

<b>Proposed Revision To:</b> <input type="checkbox"/> Standard Specifications For Public Works Construction <input type="checkbox"/> Standard Plans For Public Works Construction		<b>Change No. 172NS</b>  (ASSIGNED BY GREENBOOK COMMITTEE)
Public Works Standards, Inc. AGC Southern California Regional Office 1255 Corporate Center Dr., Suite #100 Monterey Park, California 91754		<b>Date Proposal Received</b>  <b>July 20, 2006</b>  (ASSIGNED BY GREENBOOK COMMITTEE)
<b>Subsection or plan to be revised: 302-5.8 Manholes (and other structures)</b>		<b>On page(s): 241</b>
<p><b>Revision:</b> Sewer and storm drain structures extending 50mm (2 inches) or more above the new <del>subgrade</del> <u>grade upon which the pavement surface is to be placed</u> shall be removed by the Contractor to, <u>or below</u>, the new <del>subgrade</del> <u>grade</u> before paving.</p>		
<p><b>Reason For Revision:</b> In many jurisdictions the inspection staff responsible for the roadway is not responsible for inspection of the sewer or storm drain. A conflict arises when a new road is constructed with a substantial Traffic Index and a lower R-Value. Due to the maximum allowable grade rings and the structural section of the new roadway, inspectors have required that the manhole cones be removed and plated prior to placement of aggregate base upon the compacted native soil (subgrade) because the manhole projected 2 or more inches above the new subgrade. This is in spite of the fact that the aggregate base section to be placed upon the new subgrade was 1.45' and the asphalt pavement to be placed upon the new aggregate base was .35'. After the upper portions of the manholes are reconstructed the pavement repairs were approximately 300 to 350 square feet each.</p>		
Submitted By: <u>Joe Stone</u> Phone No: <u>(951) 489-6872</u>  Agency: <u>Highland Fairview Properties</u>  Address: <u>24525 Alessandro Blvd., Moreno Valley, CA 92553</u>		
<p><b>Instructions:</b> Use a separate form for each revision. Use plain paper attached to this form if more space is needed. For minor changes, copy present wording using <del>strike over</del> with dashes for words to be deleted and <u>underline new</u> text. For major changes, rewrite or add paragraph or section. Reason MUST be given.</p>		
<b>Subcommittee Action:</b> On _____ (Date) <input type="checkbox"/> Recommended For _____ Supplement/Edition <input type="checkbox"/> Rejected <input type="checkbox"/> As Modified		<b>Editorial Standards Subcommittee Review:</b> On _____ (Date) <input type="checkbox"/> Reviewed For Surf/Und/Spec/Plans Subcommittee <input type="checkbox"/> NO Modifications <input type="checkbox"/> As Modified
<b>Greenbook Committee Action:</b>  On _____ (Date) <input type="checkbox"/> Approved For _____ Supplement/Edition <input type="checkbox"/> As Modified <input type="checkbox"/> Rejected		