

# **Greenbook Committee of Public Works Standards, Inc. Editorial Standards Subcommittee**

**February 8, 2024  
Minutes**

**Location:** via “MS Teams Meeting [Click here to join the meeting](#)

Meeting ID: 258 325 740 668 Passcode: t2MZRa **Or call in (audio only)** [+1 323-776-6996,,144984997#](#) United States, Los Angeles Phone Conference ID: 144 984 997#

**Time:** 9:00 a.m.

## **Agenda:**

### **I. Call to Order/Attendance:**

### **II. Approval of Minutes of the November 9, 2023 Meeting:**

### **III. Old Business:**

1. Change 332 UM – Causes for Rejection of PRCB. Section 216-7.

It was discussed that the proposed idea of inspection should be noted in “Section 306-10.1.2. Repairs” and not in 216-7.

We also wanted to know if the criteria in section 216-7 is different from AASHTO R-73? If R-73 has better criteria than it should be added to 216-7. Or if 216-7 is adequate than it should be referenced in 306-10.1.2. We should only have 1 criteria.

### **IV. New Business:**

1. Change 335 SP – Microtrenching  
136 SP: Add another note: all pavement replacement should not be less than 4’ from the curb to edge of patchback. Note 19.a:  
Note “17. .... RESTORATION SHALL BE THE FULL WIDTH AND FOLLOW NOTE 16 FOR .....”

### **V. Other:**

1. 321 UM “Pickle Jar” revision will be submitted by UM to be reviewed at our next meeting.

### **VI. Next Meeting:** March 14, 2024 @ 9 a.m.

### **VII. Adjournment:**