

UNDERGROUND MATERIALS AND METHODS  
SUBCOMMITTEE MINUTES  
February 13, 2018  
1906 West Garvey Ave  
West Covina, CA 91790

I. Meeting called to order 11:00 AM followed by self-Introductions

<u>NAME</u>	<u>AGENCY/COMPANY</u>	<u>TELEPHONE</u>	<u>EMAIL</u>
<u>ADDRESS</u>			
*Curt Gilley	Terrain Eng./AGC	916-952-0704	<a href="mailto:Cgilley@terrainengineering.com">Cgilley@terrainengineering.com</a>
Keegan Fahey	LA Co DPW	626-458-3190	<a href="mailto:KFahay@dpw.lacounty.gov">KFahay@dpw.lacounty.gov</a>
Gary Futral	Gadding McBean	626-676-0902	<a href="mailto:gary.futral@gladdingmcbean.com">gary.futral@gladdingmcbean.com</a>
Hal Schillinger	Forterra	951-348-8173	<a href="mailto:hal.schillinger@forterrabp.com">hal.schillinger@forterrabp.com</a>
Jamie L. Lienberger	Lienberger and Assoc	386-846-9719	<a href="mailto:Sauphtale@yahoo.com">Sauphtale@yahoo.com</a>
Mike Murphy	OldCastle	951-830-9188	<a href="mailto:mike.murphy@oldcastle.com">mike.murphy@oldcastle.com</a>
Dennis Phinney	Dennis Phinney Eng	949-929-2760	<a href="mailto:dennis@dennisphinney.com">dennis@dennisphinney.com</a>
Victor Bermudez	LA CO DWP	626-688-8275	<a href="mailto:Vbermudez@dpw.lacounty.gov">Vbermudez@dpw.lacounty.gov</a>
Rosann Paracuelles	LA County San	562-908-4288	<a href="mailto:rparacuelles@lacsod.org">rparacuelles@lacsod.org</a>
Rob Hunning	City of LA PW	213-485-1679	<a href="mailto:robert.huning@lacity.org">robert.huning@lacity.org</a>
Mattas Farfan	City of LA PW	213-485-5762	<a href="mailto:mat.farfan@lacity.org">mat.farfan@lacity.org</a>
Aidan Rajsing	Thompson Pipe Grp	323-841-2067	<a href="mailto:Arajsing@thompsonpipegroup.com">Arajsing@thompsonpipegroup.com</a>
*Micheal Wineburg			
*Alison	LADWP		

- \* Denotes remote attendance via WebEx or Teleconference

\*\* Committee Chair

Call to Order: 11:00 am

Self Introductions

**Old Business:** discussion of manhole specification. Group spent time revising the specification, will continue to next month.

CG – Safety ledges in manholes

EU – LA county has done away with ledges and uses ladders

DAN – in any manhole over 20VF deep there is a slab resting point, this is common in storm sewer manholes. CG and EU discuss bringing the slab ledge into the specification – City of Los Angeles or a precaster could sponsor this change.

DAN – has changes to submit to the city

DB – we have one year to work on this change Standard plans group has no precasters attending their meetings.

MM states mix design is the biggest issue, states his company uses a superior mix design well above what is specified.

CG get joints defined, shiplap, etc tongue and groove make is streamlined

**New Business:** Get CG a list of GB attendees for the 2018 greenbook

Adjourn: 12:20

**A. Next meeting: March 13, 2018**

*Jamie L. Lienberger - Secretary*

*Lienberger and Associates*

*386-846-9719*