

**NEW MATERIALS AND METHODS-UNDERGROUND  
SUBCOMMITTEE MINUTES**

**June 16, 2015**

**11:00am**

**AGC Offices**

**1906 West Garvey Avenue  
West Covina, CA 91790**

I. Meeting called to order followed by self-introductions at 11:08 a.m.

<u>NAME</u>	<u>AGENCY/COMPANY</u>	<u>TELEPHONE</u>	<u>E-MAIL ADDRESS</u>
Dave Badgley (DB) (Chair)	Vylon/Cretex	(818) 843-3318	dbadge@aol.com
Emilio Cervantes (EC)	Thompson Pipe Group	(909) 503-6007	ecervantes@thompsonpipegroup.com
Bill DeJong (BDe)	ADS	(714) 394-8922	bill.dejong@ads-pipe.com
Bryce Ducharm (BD)	Thompson Pipe Group	(949) 939-6339	bducharm@thompsonpipegroup.com
Roger Kohlenberger (RK)	L.A. County D.P.W./CON	(626) 458-4964	rkohlenb@dpw.lacounty.gov
Raffi Massabki (RM)	City of Los Angeles BOE	(213) 485-3510	raffi.massabki@lacity.org
Rosann Paracuelles (RP) *	L.A. County San. District	(562) 908-4288 x1637	rparacuelles@lacsds.org
Michael Prayoonvech (MP)	Thompson Pipe Group	(951) 337-0314	mprayoonvech@thompsonpipegroup.com
Russell Tripp (RT)	CA Precast Conc. Pipe Assoc.	(951) 220-7062	rtripp@concrete-pipe.org
Erik Updyke (EU)	L.A. County D.P.W./CON	(626) 458-4914	eupdyke@dpw.lacounty.gov

\* denotes remote attendance via WebEx or teleconference.

Meeting minutes of February, March, April, and May 2015 were approved as submitted.

II. Old Business:

A. Change 266NU Polypropylene Pipe: This Change is with Editorial Standards subcommittee. No discussion.

B. Part 5 – Editorial Changes: DB distributed outlines of the Part 5 structure. EU commented that “Materials” should be included under the “Installation” heading since they’re unique to the lining process. If video inspection is typically conducted pre- and post-cleaning as well as post-installation, the provisions need to include all instances and payment for such. A remedy must be provided for results of QC testing which don’t meet specified requirements. EU stated that QC testing which applies for all processes should be included under a separate heading, otherwise it’s to be included under each process. The heading for 500-1.5.6 should read only “Installation” [with “and Field Inspection” deleted].

C. New Business:

1. A vendor consultant from Houston, TX asked for a copy of the Chemical Resistance Test. EU will consider a response as test methods are generally not included in specifications.
2. The subcommittee needs to solicit input from tunneling/jacking suppliers in order to improve the provisions under Section 307 – Jacking and Tunneling.

III. Adjourned: 12:47 p.m.

VI. Next meeting: July 14, 2015 at 11:00 a.m.

*Roger Kohlenberger, Secretary  
Los Angeles County Department of Public Works  
(626) 458-4964*